



SED 2021 Tree Trimming Schedule

Type (Roadside or Off road)	ROW Width	Pole Start	Pole End	Approx. Mileage	Description	Approximate Start Date
Off road	50	2-159	2-223	3	Nebraska Valley & side taps	
Roadside	50	p 5-19	p 5-26	0.2	Mtn Rd pine trees by Edson Hill Rd, Clean up logs	
Roadside	50	4-87	4F-22	1.25	Taber Hill to Cross Rd & side taps	10/12/2021
Off road	50	4F-14	4F-20	0.1	Magoon Pasture Rd/ Cross Rd - Danger trees	
Off/On Road	50	2-34-26	2-34-52	1.5	Route 100 - 3 phase & side taps	

Typical Right-of-Way:

The typical right-of-way is fifty (50) feet in total width for aerial distribution and one-hundred (100) feet in total width for aerial transmission. Electric right-of-way maintenance shall include adequate clearance of all active overhead utilities utilizing the right-of-way, including clearing vegetation from poles and guys. There is a twenty-five (25) foot radius right-of-way for utility poles.

Clearing Distance:

All distribution line right-of-ways must be cleared to twenty-five feet (25') each side from the center energized conductor. All transmission line right-of-ways must be cleared to fifty feet (50') each side from the center energized conductor. All overhanging limbs must be removed unless there are special unsafe conditions that would prevent removal.



SED 2021 Tree Trimming Schedule

